



UL Verification Services Inc.  
7036 Snowdrift Road  
Allentown, PA 18106  
610-774-1300

## Performance Test Report

### Relevant Standards

ENERGY STAR® Luminaires v2.2

ANSI C82.77-2014, ANSI C82.2-2002, ENERGY STAR Start Time Test Method

ANSI/IEEE C62.41.1-2002, ANSI/IEEE C62.41.2-2002

### Prepared For

**RBW Studio LLC**

Reland Boyle

67 34th St, Mailbox 5, Unit 6A

Brooklyn, NY 11232

### Catalog Number

**AllSew Pendant 36"**

### Order Number

**13247821**

### Test Number

**13247821.03**

### Test Date

**2020-03-02**

### Prepared By

Cordaryl Cousar, Technician

### Approved By

Kevin Rodriguez, Project Handler

The results contained in this report pertain only to the tested sample.

This report shall not be reproduced, except in full, without written approval of Underwriters Laboratories.



UL Verification Services Inc.  
7036 Snowdrift Road  
Allentown, PA 18106  
610-774-1300

Description: Formed White canopy, frosted lens enclosure  
Lamp: 88 white LEDs  
Ballast/Driver: One ERP PSB50W-1200-42 LED Driver  
Mounting: Pendant

Sample



Electrical Values		Operating Frequency	Dimming Percentage
Test Temperature:	24.5 °C	N/A	N/A
Voltage:	120.0 VAC	Start Time	Noise
Current:	0.3394 A	79.8 ms	N/A
Power:	39.85 W	Transient Protection	
Power Factor:	0.978	N/A	
Frequency	60 Hz		
Current THD	12.5 %		

Start Time

